



ROC L-16 092461

FIRE EQUIPMENT SALES
AND SERVICE CORPORATION

ROC L-67 092462

3107 W. VIRGINIA AVE. ★ PHX, AZ 85009-1804 ★ (602) 433-2484 ★ Fax (602) 433-9626
2921 S. KISH AVE ★ YUMA, AZ 85365 ★ (928) 341-0025 ★ Fax (928) 341-0356
SHOW LOW ★ PINETOP ★ LAKESIDE ★ (928) 832-3292

10/29/2012

Jeff Akins
Blue Ridge High School Main
1200 W. Mountain Bl.
Lake Side, Az. 85929

Phone: 928-369-3945
E-Mail: jakins@brusdk12.az.us
DNR#: SLM176

RE: Fire alarm repairs per system report dated 7/30/2012. TECHNOLOGY OFFICE pg. 3

American Fire Equipment Sales & Service would like to present you with the following proposal for the above referenced facility.

Deficiencies Noted

- ▶ Manual pull in Rm. 564, next to boy's showers ties in directly to the data loop & shorts the loop when activated.
- ▶ Manual pull 1-28 in North Hall Center is addressed N. OT by Room 5.
- ▶ Horns & strobes are mixed with older mechanical type and newer simplex horn strobes. Strobes are not synchronized.
- ▶ Wrestling room old mechanical horn strobe that does not function.

Scope of Work

- ▶ Install monitor module and program for pull station device.
- ▶ Reprogram manual pull station device 1-28 to report correctly.
- ▶ Program panel / devices so all horn/strobes are synchronized.
- ▶ Replace horn/strobe in wrestling room.

Cost Summary

American Fire Equipment is pleased to provide and complete the above scope of work for the sum of:

Total Labor	\$1,360.00
Total Materials	\$362.00
Sub Total	\$1,722.00
Tax	\$33.67
Total Proposal	<u>\$1,755.67</u>